



Drain for Fire Risers

	Fire Extinguishers
	Fire Alarm Control Panel



South JH

Level 2 Fire Extinguishers

09/19/2016

1" = 42'-0"



Fire Extinguishers

ID#	Building Rm Number	Building Rm Name	Comments	MFG ID	Size	Class	Type	Serial #	New	Last Hydro	Next Hydro	Last 6 Year	Next 6 Year	Aug 14 Service
1	231	Science		Amerex	5#	ABC	DC	JL-379090	1990	2006	2018	2012	2024	X
2	229	Science		Buckeye	5#	BC	CO2	X-21744	1990	2006	2018	2012	2024	X
3	227	Science		Amerex	10#	ABC	DC	JG-279771	1985	2007	2019	2013	2025	X
4	225	Science		Amerex	5#	ABC	DC	ZT-598913	2008		2020	2014	2026	6YR
5	223	Science		Amerex	10#	ABC	DC	JG-263103	1990	2006	2018	2012	2024	X
6	221	Science		Amerex	5#	BC	CO2	W-593784	1996	2011	2016	N/A	N/A	X
7	244	Room		Amerex	10#	ABC	DC	JG-279769	1990	2006	2018	2012	2024	X
8	.	Lobby	By Room 101	Ansul	5#	ABC	DC	FN-346391		2009	2021	2012	2027	X
	.	Kitchen		Amerex	5#	ABC	DC	BF-553044	2012		2024		2018	X
9	159	Industrial Tech	Door	Amerex	10#	BC	CO2	W-574420	1996	2011	2016	N/A	N/A	X
10	159	Industrial Tech	Post	Amerex	10#	ABC	DC	KT-271025	1993	2006	2018	2014	2024	6YR
12	162	Boiler Room		Amerex	20#	ABC	DC	MC-116195	1994	2006	2018	2012	2024	X
13	.	Grounds Equip	Storage by Door 5	Amerex	5#	ABC	DC	PN-867771		2011	2023		2017	X
14	.	Grounds Equip	Storage by Door 5	Amerex	10#	ABC	DC	SG-279597	1990	2006	2018	2012	2024	X
15	.	Grounds Equip	Storage by Door 5	Amerex	10#	ABC	DC	RX-037925	2000	2012	2024		2018	X
16	.	Grounds Equip	Storage by Door 5	Amerex	10#	BC	CO2	W-574422	1996	2011	2016	N/A	N/A	X
17	118	Teachers Lounge												